


COMMONWEALTH OF MASSACHUSETTS

BOARD OF HEALTH

OF Leverett



Individual Sewage Disposal System Construction Permit

Permit to Construct (X) or Repair () an Individual Sewage Disposal

at Rd. 75 PRIME?
Road 700' N. and NE. of end of road

Star Route Montague MA 01351

Elm Street, So. Deerfield, MA 01373

Size Lot 20,000 Sq. feet

3 Expansion Attic () Garbage Grinder () NO
No. of persons Showers () — Cafeteria ()

gallons per person per day. Total daily flow 300 gallons.

gallons Length Width Diameter Depth

Width 3.0' Total Length 50 Total leaching area 150 sq. ft.

Depth below inlet Total leaching area sq. ft.

Dosing tank ()

signed by Miles J. Hubler P.E. Date 5-10-73

per inch Depth of Test Pit 36" Depth to ground water 75' or more

per inch Depth of Test Pit Depth to ground water

soil ok loose, 6"-18" silty sand SM
and SW loose

answer when applicable

I hereby certify that the above described Individual Sewage Disposal System is in accordance with the Sanitary Code — The undersigned further agrees not to place the system in place has been issued by the board of health.

Signed William A. Carey 12/9/74

Date


Date

ing reasons:

Date

Issued

Date



SKETCH SHOWING
SANITARY SEWAGE
DISPOSAL FOR LOT OFF
SPRINKLE ROAD

NO SCALE

5-10-73